

AN AMENDMENT OR AMENDMENTS TO ORDINANCE NO. 95-5-1
(AN ORDINANCE ESTABLISHING AND REVISING RULES, RATES,
PROCEDURES REGULATIONS AND STANDARDS FOR THE OPERATION OF
THE SANGAMON VALLEY PUBLIC WATER DISTRICT IN CHAMPAIGN
COUNTY, ILLINOIS)

July 26, 2005
Changes to be effective September 1, 2005

The ORDINANCE is amended as follows:

SECTION 3 – WATER REGULATIONS

3.12 – User Responsibility

(2nd Subparagraph)

Currently READS:

The user shall be responsible for installation and maintenance of service lines between the District's water main and the residence or business. Such services must be at least 3/4" in diameter, and must be installed at a minimum depth of 4 feet. Service lines must have a minimum working pressure rate of 200 psi at 73.4 degrees F and must be constructed of following type of material: SDR - 9, Copper Tube Size polyethylene water pipe (ASTM D2737). Lines larger than two inches shall be PVC, SDR - 21 (ASTM B2241) conforming to water main line specifications as described in Section 6.2 of this document. Service lines must not be covered until they are inspected and approved by a duly authorized District representative. The user will not connect any service line or any plumbing connected with the service line to any other water source. The service line must meet all requirements of the State Environmental Protection Agency and the State of Illinois Plumbing Code.

AMEND SECTION 3 – WATER REGULATIONS

3.12 – User’s Responsibility

(2nd Subparagraph)

Amended to READ:

The user shall be responsible for installation and maintenance of service lines between the District's water main and the residence or business. Such services must be at least 1” in diameter, and must be installed at a minimum depth of 4 feet. Service lines must have a minimum working pressure rating of 200 psi at 73.4 degrees F and must be constructed of following type of material: SDR - 9, Copper Tube Size polyethylene water pipe (ASTM D2737). *The District reserves the right to require an increased water service line size or installation of an additional water service line to the existing service in order to provide adequate water supply to proposed water usage systems within residential or business properties. If, for example, a proposed residential property has more than 4 bedrooms or 4 bedrooms or more with a fire suppression system and or an outside irrigation system, the plumbing contractor shall demonstrate the calculations for the sizing of the water service line by use of the Illinois Plumbing Code Section 890-1200 prior to issuance of the water/sewer installation permit.*

. Lines larger than two inches shall be PVC, SDR - 21 (ASTM B2241) conforming to water main line specifications as described in Section 6.2 of this document. Service lines must not be covered until they are inspected and approved by a duly authorized District representative. The user will not connect any service line or any plumbing connected with the service line to any other water source. The service line must meet all requirements of the State Environmental Protection Agency and the State of Illinois Plumbing Code.