

AN AMENDMENT OR AMENDMENTS TO ORDINANCE NO. 95-5-1
(AN ORDINANCE ESTABLISHING AND REVISING RULES, RATES, PROCEDURES
REGULATIONS AND STANDARDS FOR THE OPERATION OF THE SANGAMON
VALLEY PUBLIC WATER DISTRICT IN CHAMPAIGN COUNTY, ILLINOIS)

December 19, 2002
(Changes to be effective January 1, 2002)

The ORDINANCE is amended as follows:

SECTION 4 – WASTEWATER REGULATIONS

4.8 – User’s Responsibility

(9th Subparagraph)

Currently READS:

Whenever possible, the building sewer to serve a new building shall be brought to the building at an elevation below the basement floor. In all buildings, which any building drain is too low to permit gravity flow to the public sewer, sanitary sewage carried by such building drain shall be lifted by a means which is approved by the District and discharge to the building sewer. No water operated sewage ejector shall be used. The minimum depth of cover shall afford protection from frost. The building sewer shall be laid at a uniform grade and in straight alignment, insofar as possible. Changes in direction shall be made only with properly curved pipe and fittings, unless the break in the line is made at the manhole to facilitate servicing. All building drains shall be equipped with a proper "clean-out" outside the building to facilitate access to the service line for cleaning.

AMEND SECTION 4 – WASTEWATER REGULATIONS

4.8 – User’s Responsibility

(9th Subparagraph)

To READ:

Whenever possible, the building sewer to serve a new building shall be brought to the building at an elevation below the basement floor *or crawl space. No below grade plumbing fixtures shall be directly connected by gravity to any portion of the building sewer. Construction of all building drains shall be no lower than the ground floor of any building. Sanitary sewage from all below grade plumbing fixtures shall be lifted by a means which is approved by the District and discharged to the building sewer.* No water operated sewage ejector shall be used. The minimum depth of cover shall afford protection from frost. The building sewer shall be laid at a uniform grade and in straight alignment, insofar as possible. Changes in direction shall be made only with properly curved pipe and fittings, unless the break in the line is made at the manhole to facilitate servicing. All building drains shall be equipped with a proper "clean-out" outside the building to facilitate access to the service line for cleaning.